



Certificate of Compliance

Certificate: 1118979 **Master Contract:** 165016 (LR 5835)

Project: 70076212 **Date Issued:** 2016-08-09

Issued to: Federal Signal Corporation
2645 Federal Signal Dr
University Park, Illinois 60484
USA
Attention: Sean Moloney

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Yiu-Chi (Edwin) Ko
Yiu-Chi (Edwin) Ko

PRODUCTS

CLASS - C481285 - SIGNAL APPLIANCES-Signaling Systems - Certified to US Standards

CLASS - C481213 - SIGNAL APPLIANCES-Signal Systems

Audio/Visual Signaling Appliances, Models AV1, AV1LED, AV1ST, rated 120V ac, 60Hz, 0.27A, 0.10A, 0.15A; and 24V dc, 0.98A, 0.16A, 0.39A for indoor/outdoor use, Type 3R enclosure.

APPLICABLE REQUIREMENTS

- CSA C22.2 No. 205-12 - Signal equipment
- UL 1638 4th Edition - Visual Signaling Appliances - Private Mode Emergency and General Utility Signaling
- UL 464 9th Edition - Audible Signaling Appliances



Supplement to Certificate of Compliance

Certificate: 1118979

Master Contract: 165016 (LR 5835)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70076212	2016-08-09	Update report to cover report update to CSA C22.2 No. 205-12 and change of class from C4812 05 to C4812 13.
2755099	2014-08-21	Added alternate enclosure plastic material for AV1 Model Series
1863025	2006-12-21	Update to 1118979 to cover report changes.
1187653	2001-05-22	Update report to cover CUS requirements.
1118979	2000-10-11	Original Certification.