



# Certificate of Compliance

**Certificate:** 1126286

**Master Contract:** 165016

**Project:** 2755098

**Date Issued:** August 21, 2014

**Issued to:** Federal Signal Corporation

2645 Federal Signal Dr  
University Park, IL 60484  
USA  
Attention: Sean Moloney

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



*Jihan Gunaratne*

**Issued by:** Jihan Gunaratne

## **PRODUCTS**

**CLASS 4812 05** - SIGNAL APPLIANCES - Systems

**CLASS 4812 85** - SIGNAL APPLIANCES - Signaling Systems - Certified to US Standards

Visual Signaling Appliance, Models LP3 and LP6 strobe, rated 120V ac, 50/60Hz, 0.10A, 230-240V ac, 50/60Hz, 0.07A and 12-48V dc, 0.44-0.10A, for indoor/outdoor use, Type 4X enclosure.

Visual Signal Appliance, Model LP3 Incandescent, rated 12V dc, 1.04A; 24V dc, 0.67A; 120V ac, 50/60Hz, 0.13A.

Visual Signal Appliance, Model LP3 LED, rated 24V ac/dc, 50/60Hz, 0.080A; 120V ac, 50/60Hz, 0.045A.

Note: The Model LP3 may have a suffix to denote the mounting base method and Lead Wire Configuration.



**Certificate:** 1126286

**Master Contract:** 165016

**Project:** 2755098

**Date Issued:** August 21, 2014

---

**APPLICABLE REQUIREMENTS**

CSA Std C22.2 No 205-M1983 - Signal Equipment

CAN/CSA-C22.2 No 94-M91 - Special Purpose Enclosures

UL Std No 1638 - Visual Signalling Appliances