



Certificate of Compliance

Certificate: 1398389 (LR 11170-29)

Master Contract: 165016

Project: 2438706

Date Issued: July 11, 2011

Issued to: Federal Signal Corporation

2645 Federal Signal Dr
University Park, IL 60484
USA
Attention: Sean Maloney

The products listed below are eligible to bear the CSA Mark shown



Marius Manastireanu

Issued by: Marius Manastireanu

PRODUCTS

CLASS 4818 03 - SIGNAL APPLIANCES - Miscellaneous - For Hazardous Locations

Class I, Div. 2, Groups A, B, C and D; Class II, Div.2, Groups F and G; Class III; Type 4X;

Intercoms, Models 310X-MV and AD-28X-MV; Rated 24V dc or 120/240V, 50/60Hz, 0.26A max

APPLICABLE REQUIREMENTS

CAN/CSA Standard C22.2 No. 0-10	General requirements – Canadian Electrical Code, Part II
CAN/CSA Standard C22.2 No. 25-1966	Enclosures for use in Class II, Groups E, F and G Hazardous Locations
CAN/CSA Standard C22.2 No. 94-M91	Special Purpose Enclosures
CAN/CSA Standard C22.2 No. 205-M1983	Signal Equipment
CAN/CSA Standard C22.2 No. 213-M198	Non-Incendive Electrical Equipment for use in Class I, Div 2 Hazardous Locations



Certificate: 1398389 (LR 11170-29)

Master Contract: 165016

Project: 2438706

Date Issued: July 11, 2011

MARKINGS

The following markings appear on a CSA Certified (Class 7921-01) adhesive label.

- Manufacturer's name: "Federal Signal Corporation", or CSA Master Contract Number "165016", adjacent to the CSA Mark in lieu of manufacturers name.
- Model Number: As specified in the PRODUCTS section, above.
- Electrical ratings: As specified in the PRODUCTS section, above.
- Manufacturing date in MMY format, or serial number, traceable to month of manufacture.
- Enclosure ratings: As specified in the PRODUCTS section, above.
- The CSA Mark, as shown on the Certificate of Compliance.
- Hazardous Location designations: As specified in the PRODUCTS section, above (may be abbreviated).
- The following words:

"Caution: DO NOT DISCONNECT WHILE CIRCUIT IS LIVE UNLESS THE AREA IS KNOWN TO BE NON-HAZARDOUS" or equivalent.