



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7125-0811:0132
CATEGORY:	7125 - FIRE ALARM DEVICES FOR THE HEARING IMPAIRED
LISTEE:	Federal Signal 2645 Federal Signal Drive, University Park, IL, 60466 Contact: Moloney, Sean (708) 587-3324 (708) 534-4878 Email: smoloney@federalsignal.com
DESIGN:	Model FB24STHI strobe light for the hearing impaired. Refer to listee's data sheet for additional product description and operational considerations.
RATING:	Candela: 15 cd Electrical: *24 VDC
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed as strobe lights for use with separately listed compatible fire alarm control units. Suitable for the hearing impaired application *(with clear lens only). Intended for use on wall or ceiling in non-sleeping areas. For indoor use only. Enclosure is rated Type 4X and IP66.
NOTES:	

*Rev. 02-03-04



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 04/10/2025

Listing Expires: 06/30/2026

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division