

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7125-0811:0132 Page 1 of 1

**CATEGORY:** 7125 -- FIRE ALARM DEVICES FOR THE HEARING IMPAIRED

**LISTEE:** Federal Signal 2645 Federal Signal Drive, University Park, IL 60466-3195  
Contact: Sean Moloney (708) 587-3324 Fax (708) 534-4878  
Email: smoloney@federalsignal.com

**DESIGN:** Model FB24STHI strobe light for the hearing impaired. Refer to listee's data sheet for additional product description and operational considerations.

**RATING:** Candela: 15 cd  
Electrical: \*24 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as strobe lights for use with separately listed compatible fire alarm control units. Suitable for the hearing impaired application \*(with clear lens only). Intended for use on wall or ceiling in non-sleeping areas. For indoor use only. Enclosure is rated Type 4X and IP66.

**NOTE:**

\*Rev. 02-03-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2014**

Listing Expires **June 30, 2015**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**  
*Fire Engineering Division*