

CERTIFICATE OF COMPLIANCE

Certificate Number 20121212-E4813J
Report Reference E4813-20041130
Issue Date 2012-DECEMBER-12

Issued to: FEDERAL SIGNAL CORP SIGNAL DIV
2645 FEDERAL SIGNAL DR
UNIVERSITY PARK IL 60484


**This is to certify that
representative samples of**

AUDIBLE SIGNAL APPLIANCES, GENERAL SIGNAL
Indoor Electronic Siren Controller, Model UVIC, may be
followed by L, H or U, may be followed by 240, may be
followed by S or A, may be followed by IP or SAT2.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 464, Audible Signal Appliances
Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

