

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20121212-E4813U  
**Report Reference** E4813-20070222  
**Issue Date** 2012-DECEMBER-12

**Issued to:** FEDERAL SIGNAL CORP SIGNAL DIV  
2645 FEDERAL SIGNAL DR  
UNIVERSITY PARK IL 60484

**This is to certify that  
representative samples of**

AUDIBLE SIGNAL APPLIANCES, GENERAL SIGNAL;  
SPEAKERS

See Addendum Page

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.


**Standard(s) for Safety:**  
**Additional Information:**

UL 464, Audible Signal Appliances


See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and

"US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20121212-E4813U  
**Report Reference** E4813-20070222  
**Issue Date** 2012-DECEMBER-12

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Audible Signal Appliances For General (Non-Fire) Service, Model 50GC when used with Federal Signal's Listed plug-in module, Model TC-HL, -HN, -WL, -YP, -YW, TM2, TM33, UTC, or UTM. Suitable for Indoor/Outdoor Use, Wet Locations, TYPE 1, Operating Ambient -55 °C to +66 °C. TYPE 3R when used with WB backbox.

Audible Signal Appliances For General (Non-Fire) Service, Model 50GCB when used with Federal Signal's Listed plug-in module, Model TC-HL, -HN, -WL, -YP, -YW, TM2, TM33, UTC, or UTM. Suitable for Indoor/Outdoor Use, Wet Locations, TYPE 1, Operating Ambient -55 °C to +66 °C.

Signaling Speaker For General (Non-Fire) Service, Model 50GC when used with Federal Signal's Listed plug-in module, Model EM3, 300CK, E-300CK, T-300CK, 300CKS, AM25CK, AM70CK, CK25, or CK70. Suitable for Indoor/Outdoor Use, Wet Locations, TYPE 1, Operating Ambient -55 °C to +66 °C. TYPE 3R when used with WB backbox.

Signaling Speaker For General (Non-Fire) Service, Model 50GCB when used with Federal Signal's Listed plug-in module, Model EM3, 300CK, E-300CK, T-300CK, 300CKS, AM25CK, AM70CK, CK25, or CK70. Suitable for Indoor/Outdoor Use, Wet Locations, TYPE 1, Operating Ambient -55 °C to +66 °C.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

