

CERTIFICATE OF COMPLIANCE

Certificate Number 20130730-E162485
Report Reference E162485- 20031014
Issue Date 2013-JULY-30

Issued to: FEDERAL SIGNAL CORP SIGNAL DIV
2645 FEDERAL SIGNAL DR,
UNIVERSITY PARK IL 60484

This is to certify that representative samples of VISUAL-SIGNAL APPLIANCES
See Addendum Page for Models/Product

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1638, Visual Signaling Appliance - General Utility Signaling
CAN/CSA C22.2, No. 205-M1983 Signal Equipment.

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130730-E162485
Report Reference E162485- 20031014
Issue Date 2013-JULY-30

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

General Signaling Equipment:

USL, CNL - Visual signal appliances, Model 121, may be followed by suffix A, indicating 12/24 V dc operation, or suffix S, indicating 120 V ac operation. If no suffix is provided, then the unit utilizes a magnetic base and a cigarette lighter type cord/plug assembly operating at 12 V dc. Intended for indoor/outdoor use. Environmental rating Type-3R may be applied when Model LWMB2 or LWMC2 mounting brackets are employed with the lens in the upward position.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

