

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20160928 - E84580  
**Report Reference** E84580-19930730  
**Issue Date** 2016-SEPTEMBER-28

**Issued to:** FEDERAL SIGNAL CORP SIGNAL DIV  
2645 FEDERAL SIGNAL DR  
UNIVERSITY PARK IL 60484

**This is to certify that  
representative samples of**

SIGNAL APPLIANCES, MISCELLANEOUS FOR USE IN  
HAZARDOUS LOCATIONS,  
VISUAL-SIGNAL DEVICES, MARINE

Model 121X, beacon lights for use in hazardous locations,  
Class I, Groups C and D and Class II, Groups E, F and G,  
Class III; for indoor or outdoor use, Type 4X enclosure.  
Also Listed as a marine visual signal device.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** See Addendum Page For Standards  
**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20160928 - E84580  
**Report Reference** E84580-19930730  
**Issue Date** 2016-SEPTEMBER-28

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

UL 1203 Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations  
CAN/CSA C22.2 No. 25-1966, Enclosures for Use In Class II Groups E, F, and G Hazardous Locations  
CAN/CSA C22.2 No. 30-M1986, Rev. 1988-11, Explosion-Proof Enclosures for Use in Class Hazardous Locations  
ANSI/ISA 12.12.01-2012, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations  
CSA C22.2 No. 213-M1987, Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations  
UL 50E Enclosure for Electrical Equipment, Environmental Considerations  
UL 50 Enclosures for Electrical Equipment, Non-environmental Considerations  
CAN/CSA C22.2 94.2-07, Enclosures for Electrical Equipment, Environmental Considerations,  
UL 1638, 4th Ed., Rev. 2008-10-10, Visual Signaling Appliances – Private Mode Emergency and General Utility Signaling  
CAN/CSA C22.2 No. 205-M1983, Signal Equipment First Edition, General Instructions No. 1



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

