

CERTIFICATE OF COMPLIANCE

Certificate Number E207119
Report Reference E207119-20020318
Issue Date 2020-APRIL-28

Issued to: FEDERAL SIGNAL CORP SIGNAL DIV
2645 FEDERAL SIGNAL DR
UNIVERSITY PARK IL 60484-3167

**This certificate confirms that
representative samples of**

VISUAL-SIGNAL APPLIANCES FOR USE IN
HAZARDOUS LOCATIONS & VISUAL-SIGNAL DEVICES,
MARINE

Please see addendum page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:
Additional Information:

Please see addendum page

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E207119
Report Reference E207119-20020318
Issue Date 2020-APRIL-28

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models/ Product:

USL - Model 151XST and 154XST strobe lights for use in hazardous locations, Class I, Division 2, Groups A, B, C and D, Class II, Groups E, F and G, Class III.

Also Complementary Listed as a marine visual signal device (UXUB).

CNL - Model 151XST and 154XST, strobe lights for use in hazardous locations. Class I, Division 2, Groups A, B, C and D; Class II, Groups E, F and G, Class III.

USL CNL - Visual Signal Appliance Mounting Subassemblies Model No. LHWB for use in Class I, Division 2, Groups A, B, C, and D; Class II, Division 2, Groups F and G; Class III Hazardous Locations.

Standard(s) for Safety:

Standard No. ANSI/ISA 12.12.01, 2013, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations

Standard No. CAN/CSA C22.2 No. 213-M1987, Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations

UL 1638, Visual Signaling Appliances – Private Mode Emergency and General Utility Signaling,

UL 50, Enclosures for Electrical Equipment, Non-Environmental Considerations

CSA C22.2 No. 94-M91, Special Purpose Enclosures Industrial Products



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/ul/locations/>

