

CERTIFICATE OF COMPLIANCE

Certificate Number 20130802-E84580
Report Reference E84580-19950705
Issue Date 2013-AUGUST-02

Issued to: FEDERAL SIGNAL CORP SIGNAL DIV
2645 FEDERAL SIGNAL DR
UNIVERSITY PARK IL 60484

**This is to certify that
representative samples of**

SIGNAL APPLIANCES, MISCELLANEOUS FOR USE IN
HAZARDOUS LOCATIONS, SIGNAL APPLIANCES,
MARINE

Intercom, Model 310X-MV and AD-28X-MV for use in
Class I, Div. 2, Groups A, B, C and D; Class II, Div. 2,
Groups F, and G; Class III Hazardous Locations, and
Type 4X. Also, suitable for marine use.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:


Nonincendive Electrical Equipment for Use in Class I and II,
Division 2 and Class III, Divisions 1 and 2 Hazardous
(Classified) Locations, ANSI/ISA 12.12.01-2012
Non-incendive Electrical Equipment for Use in Class I,
Division 2 Hazardous Locations Industrial Products, CSA
C22.2 No. 213-M1987

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as
being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US
and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and

"US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL;
and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus

