

CERTIFICATE OF COMPLIANCE

Certificate Number 20121212-E4813A
Report Reference E4813-19651015
Issue Date 2012-DECEMBER-12

Issued to: FEDERAL SIGNAL CORP SIGNAL DIV
2645 FEDERAL SIGNAL DR
UNIVERSITY PARK IL 60484

This is to certify that AUDIBLE SIGNAL APPLIANCES
representative samples of See Addendum Page

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 464, Audible Signal Appliances
Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20121212-E4813A
Report Reference E4813-19651015
Issue Date 2012-DECEMBER-12

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Vibrating bells, Models 500, 6VAC, 12VAC, 24VAC, 120VAC and 230/240VAC, may use A4, A6 or A10 gong assembly. NEMA, Type 3R rating for indoor or outdoor use when used with the Model WB backbox.

Vibrating bells, Models 504WB, 506WB, 510WB, 6VAC, 12VAC, 24VAC, 120VAC and 230/240VAC, NEMA, Type 3R rating for indoor or outdoor use.

Vibrating bells, Models 600, 6VDC, 12VDC, 24VDC, 48VDC, 125VDC and 250VDC, may use A4, A6, or A10 gong assembly. NEMA, Type 3R rating for indoor or outdoor use when used with the Model WB backbox.

Vibrating bells, Models 604WB, 606WB, 610WB, 6VDC, 12VDC, 24VDC, 48VDC, 125VDC and 250VDC, NEMA, Type 3R rating for indoor or outdoor use.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

