

CERTIFICATE OF COMPLIANCE

Certificate Number 20130723- E12629
Report Reference E12629-20060602
Issue Date 2013-JULY-23

Issued to: FEDERAL SIGNAL CORP SIGNAL DIV
2645 FEDERAL SIGNAL DR
UNIVERSITY PARK IL 60484

This is to certify that representative samples of AUDIBLE-SIGNAL APPLIANCES FOR USE IN HAZARDOUS LOCATIONS
See addendum page

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1480 – Speakers for Fire Alarm, Emergency and Commercial and Professional Use
UL 50 – Enclosure for Electrical Equipment
ANSI/ISA-12.12.01 Standard for Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
CSA C22.2 No. 205-M1983 Standard for Signal Equipment, General Instruction No. 1
CSA C22.2 No. 213-M1987 Standard for Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations
CSA C22.2 No. 157-92 Standard for Intrinsically Safe and Non-incendive Equipment for Use in Hazardous Locations

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and

"US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130723- E12629
Report Reference E12629-20060602
Issue Date 2013-JULY-23

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL – Speakers for Fire Protective Signaling Systems, Model AM300X and AM302X for use in Hazardous Locations, Class I, Division 1, Groups B, C, and D; Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups F and G; and Class III; Suitable for Outdoor, Wet Locations Use. Also Listed as Speakers and Amplifiers for Fire Protective Signaling Systems.

USL, CNL – Signaling Speakers for General Signaling Systems, Model AM300X and AM302X for use in Hazardous Locations, Class I, Division 1, Groups B, C, and D; Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups F and G; and Class III; Suitable for Outdoor, Wet Locations Use. Also Listed as Speakers



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

