

CERTIFICATE OF COMPLIANCE

Certificate Number 20130723-E12629
Report Reference E12629-20060830
Issue Date 2013-JULY-23

Issued to: FEDERAL SIGNAL CORP SIGNAL DIV
2645 FEDERAL SIGNAL DR
UNIVERSITY PARK IL 60484

**This is to certify that
representative samples of**

**AUDIBLE-SIGNAL APPLIANCES FOR USE IN
HAZARDOUS LOCATIONS CERTIFIED FOR CANADA**

Audible Signal Appliances For General Signaling , Models SSTX-MV and SSTX3-MV for use in Class I, Division 1, Groups B, C, and D; Class I, Division 2, Groups A, B, C, and D; Class II, Division 2, Groups F and G; and Class III Hazardous Locations. Suitable for Indoor/Outdoor Use.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

C22.2 No. 25-1966 Enclosures for Use in Class II Groups E, F, and G Hazardous Locations
CSA C22.2 No. 30-M1986, Explosion-Proof Enclosures for Use in Class I Hazardous Locations
C22.2 No. 205 and C22.2 No. 213-M1987, Standard for Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations

Additional Information:

See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate Canadian requirements.

The UL Listing Mark for Canada includes: the UL Mark for Canada:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier in English, French, or English/French) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

