

CERTIFICATE OF COMPLIANCE

Certificate Number 20170921-E207119
Report Reference E207119-20160719
Issue Date 2017-SEPTEMBER-21

Issued to: FEDERAL SIGNAL CORP SIGNAL DIV
2645 FEDERAL SIGNAL DR
UNIVERSITY PARK IL 60484-3167

This is to certify that representative samples of VISUAL-SIGNAL APPLIANCES FOR USE IN HAZARDOUS LOCATIONS
See Addendum Page

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/ISA 12.12.01- 2015, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 And Class III, Divisions 1 and 2 Hazardous (Classified) Locations.
CAN/CSA C22.2 No. 213-15, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations.

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20170921-E207119
Report Reference E207119-20160719
Issue Date 2017-SEPTEMBER-21

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Visual signal devices for use in Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Group F and G, and Class III Hazardous Locations.

G Series Strobe, Model G-STR; followed by -024, -120, or -230; may be followed by -E, -D, or -T; may be followed by -C, -G, -M, -Y, -R, -A, or -B.

G Series LED, Model G-LED; followed by -DC or -AC; may be followed by -E, -D or -T; may be followed by -C, -G, -M, -Y, -R, -A, or -B.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

