

CERTIFICATE OF COMPLIANCE

Certificate Number 20161203-E211775
Report Reference E211775-20161129
Issue Date 2016-DECEMBER-03

Issued to: FEDERAL SIGNAL CORP SIGNAL DIV
2645 FEDERAL SIGNAL DR
UNIVERSITY PARK IL 60484

**This is to certify that
representative samples of**

SIGNALING APPLIANCES AND EQUIPMENT FOR THE
HEARING IMPAIRED FOR USE IN HAZARDOUS
LOCATIONS

Model 154XSTHI, Signal Appliance for the Hearing
Impaired for use in Class I, Division 2, Groups A, B, C and
D; Class II, Division 1, Groups E, F and G; Class III
Hazardous Locations. For indoor use on a wall or ceiling in
a non-sleeping area,
Type 4X and IP66 enclosure.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical
Equipment for Use in Hazardous (Classified) Locations
ISA 12.12.01-2013, Nonincendive Electrical Equipment for
Use in Class I and II, Division 2 and Class III, Divisions 1
and 2 Hazardous (Classified) Locations
UL 1971, Signaling Devices for the Hearing Impaired

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

