

CERTIFICATE OF COMPLIANCE

Certificate Number 20130725-E207119
Report Reference E207119-20090508
Issue Date 2013-July-25

Issued to: FEDERAL SIGNAL CORP SIGNAL DIV,
2645 FEDERAL SIGNAL DR,
UNIVERSITY PARK IL 60484.

**This is to certify that
representative samples of**


VISUAL AND VISUAL-AUDIBLE SIGNAL APPLIANCES,
FIRE ALARM, FOR USE IN HAZARDOUS LOCATIONS.
Model 154XST-024C-CN, strobe lights for use in hazardous
locations. Class I, Division 2, Groups A, B, C and D; Class
II, Groups E, F and G, Class III; for indoor or outdoor use,
IP66 and Type 4X enclosure.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: Visible Signal Devices for Fire Alarm Systems, Including
Accessories -C22.2 No. 25-1966, C22.2 No. 94-M91, C22.2
No. 137-M1981 and C22.2 No. 213-M1987.

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for Canada should be considered as being covered
by UL's Listing and Follow-Up Service meeting the appropriate Canadian requirements.

The UL Listing Mark for Canada includes: the UL Mark for Canada:  with the word "LISTED"; a
control number (may be alphanumeric) assigned by UL; and the product category name (product
identifier in English, French, or English/French) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus

