

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20191212-E207119  
**Report Reference** E207119-20170315  
**Issue Date** 2019-DECEMBER-12

**Issued to:** FEDERAL SIGNAL CORP SIGNAL DIV  
2645 FEDERAL SIGNAL DR  
UNIVERSITY PARK IL 60484-3167

**This is to certify that  
representative samples of**

VISUAL-SIGNAL APPLIANCES FOR USE IN  
HAZARDOUS LOCATIONS CERTIFIED FOR CANADA  
CNL Visual-signal appliance for use in Hazardous  
Locations, Class I, Division 1, Group C and D; Class I,  
Division 2, Groups A, B, C and D, Class II, Division 1,  
Groups E, F and G; Class III.  
Model: Strobe Light Model 24XSTHI-CN

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**


CSA C22.2 No. 30-M1986 - Explosion-Proof Enclosures for  
Use in Class I Hazardous Locations  
CSA C22.2 No. 25-1966 - Enclosures for Use in Class II  
Groups E, F and G Hazardous Locations  
CSA C22.2 No. 213-16 - Nonincendive Electrical Equipment  
for Use in Class I and II, Division 2 and Class III, Divisions 1  
and 2 Hazardous (Classified) Locations  
CAN/ULC-S526:2016 - Visible Signaling Devices for Fire  
Alarm and Signaling Systems, Including Accessories

**Additional Information:**

See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

