



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

|                      |  |
|----------------------|--|
| <b>LISTING No.:</b>  | 7300-0811:0133   |
| <b>CATEGORY:</b>     | 7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES   |
| <b>LISTEE:</b>       | Federal Signal 2645 Federal Signal Drive, University Park, IL, 60466<br>Contact: Moloney, Sean (708) 587-3324 (708) 534-4878<br>Email: smoloney@federalsignal.com  |
| <b>DESIGN:</b>       | Model 224XST general signaling (non-fire alarm) strobe light for use in hazardous locations, Class I, Div. 2, group A, B, C and D; Class II, Div. 2, Group F and G; and Class III. Refer to listee's data sheet for additional product description and operational considerations. |
| <b>RATING:</b>       | 120/240 VAC, 12/24 VDC   |
| <b>INSTALLATION:</b> | In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.  |
| <b>MARKING:</b>      | Listee's name, model number, electrical rating and UL label.   |
| <b>APPROVAL:</b>     | Listed as general signaling (non fire alarm) strobe lights for use with separately listed compatible fire alarm control units. Not suitable for the hearing impaired application. Intended for indoor or outdoor use. Enclosure is rated NEMA or Type 4x and IP66.                 |
| <b>NOTES:</b>        |  |

\*Rev. 06-18-2002



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 06/25/2026**

**Listing Expires: 06/30/2027**

Authorized By: **Michael Huang**, Program Coordinator  
Fire Engineering & Investigations Division