



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7125-0811:0130
<b>CATEGORY:</b>	7125 - FIRE ALARM DEVICES FOR THE HEARING IMPAIRED
<b>LISTEE:</b>	Federal Signal 2645 Federal Signal Drive, University Park, IL, 60466 Contact: Moloney, Sean (708) 587-3324 (708) 534-4878 Email: smoloney@federalsignal.com
<b>DESIGN:</b>	Model FSEX-HI strobe lights with *optional clear lens for use in hazardous locations: Class I, Division 1, Groups C and D; Class I, Division 2, Groups A and B; Class II, Groups E, F, G; and Class III. Refer to listee's data sheet for additional product description and operational considerations.
<b>RATING:</b>	Candela: 15 cd (provided with internal lens)  *Candela: 150 cd (provided without internal lens)  Electrical: 24 VDC
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, rating, and UL label.
<b>APPROVAL:</b>	Listed as strobe lights for use with separately listed compatible fire alarm control units. Suitable for the hearing impaired application. Intended for use on wall or ceiling in non-sleeping areas. For indoor use only. Enclosure is rated Type 4X. Refer to listee's Installation Instruction Manual for details.
<b>NOTES:</b>	

\*Rev. 11-29-11gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 04/10/2025**

**Listing Expires: 06/30/2026**

Authorized By: **Michael Huang**, Program Coordinator  
Fire Engineering & Investigations Division