

CERTIFICATE OF COMPLIANCE

Certificate Number 20130724-E211775
Report Reference E211775-20130227
Issue Date 2013-JULY-24

Issued to: FEDERAL SIGNAL CORP SIGNAL DIV
2645 FEDERAL SIGNAL DR
UNIVERSITY PARK IL 60484

**This is to certify that
representative samples of**

SIGNALING APPLIANCES AND EQUIPMENT FOR THE
HEARING IMPAIRED FOR USE IN HAZARDOUS
LOCATIONS

VISUAL-SIGNAL DEVICES, MARINE
Refer to addendum page for Models

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety:

UL 1971 - Signaling Devices for the Hearing Impaired, UL
1203, Explosion-Proof and Dust-Ignition-Proof Electrical
Equipment for Use in Hazardous (Classified) Locations
ISA-12.12.01, Nonincendive Electrical Equipment for Use in
Class I and II, Division 2 and Class III, Divisions 1 and 2
Hazardous (Classified) Locations

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus




CERTIFICATE OF COMPLIANCE

Certificate Number 20130724-E211775
Report Reference E211775-20130227
Issue Date 2013-JULY-24

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model 24XSTHI, Signal Appliances for the Hearing Impaired for use in Hazardous Locations, Class I, Division 1, Group C and D; Class I Division 2, Groups A, B, C and D, Class II, Division 1, Groups E, F and G; Class III Hazardous Locations.

Also Listed as a marine visual signal device.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

