

EC CERTIFICATE

CERTIFICATE OF CONSTANCY OF PERFORMANCE CERTIFICATE No. 2821-CPR-0207

In compliance with the Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product and placed on the market under the name or trademark of

Manufacturer: Federal Signal

Address: 2645 Federal Signal Dr.,
University Park, IL 60484, USA

Product: Model CP-BG-M-R-X-XXX-XX-2 Series, Manual Call Point

Places of production: Federal Signal
2645 Federal Signal Dr.
University Park, IL 60484, USA


Harmonised Standard: EN 54-11: 2001 + A1:2005 - Fire detection and fire alarm systems -
Part 11: Manual call points

Product area code: 10 - Fixed fire-fighting equipment

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the above referenced standard(s) under system 1 (or 1+) for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product**.

This certificate was first issued on 29 March 2022 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Revision: 0
Date of revision: N/A
Issued by UL International (NL) B.V. Notified Body 2821.

Signed: 
Name: Horst Thelen
Head of Notified Body


EC CERTIFICATE

Schedule for certificate No. 2821-CPR-0207

Detailed information sheet

Product Reference:	Model CP-BG-M-R-X-XXX-XX-2 series, where the model code is broken down as follows: <ul style="list-style-type: none">- X signifies the switch type, S for single switch, D for double switch and L for LED- XXX signifies the lift flap/hammer option, NNN for none, NNH for no flap no label with hammer, FNN for flap no label no hammer, FFN for flap with fire label no hammer, FNH for flap no label with hammer, FFH for flap with fire label with hammer- XX signifies the indicator LED, 00 for none, 06 for indicator LED, 6V, 12 for indicator LED, 12V, 24 for indicator LED, 24V, 48 for indicator LED, 48V
Type:	Manual Call Point, Indoor and Outdoor Use, Type A - direct operation (single action)
Description:	Break Glass Manual Call Point which is intended for fire detection and fire alarm systems for buildings
Key Performance parameters:	Operating voltage 6, 12, 24, and 48Vdc $\pm 10\%$
Identification and intended use	Product: Manual Call Point Intended use: For use in fire detection and fire alarm systems installed in and around buildings

Revision: 0
Date of revision: N/A
Issued by UL International (NL) B.V. Notified Body 2821.

Signed: 
Name: Horst Thelen
Head of Notified Body



EC CERTIFICATE

Limitations on the acceptance or use of the product(s):

Installation instructions	To be used in accordance with the suppliers installation instructions, and technical datasheet.
Limitations	As Detailed in the Installation instructions and UL Report.
UL Report:	NC28434-D01-EuropeanDirective-Original

Terms and Conditions:

1. This certificate remains the property of UL International (NL) B.V, herein "UL NL", and will be withdrawn if any conditions attached to its issue are not complied with.
2. This certificate is issued subject to the Global Services Agreement (GSA) and CPR Service Terms.
3. Production is limited to the site(s) as listed, or detailed within the Technical documentation held by UL NL.
4. Any product change, production/process changes, etc. which may affect conformity shall be notified to UL NL.
5. This certificate is only valid for placing goods on the EU market.
6. The requirements for the economic operators stipulated in CHAPTER II, Article 4 of the Regulation (EU) 2019/1020 of the European Parliament and of the Council of 20 June 2019

END OF CERTIFICATE

Revision: 0
Date of revision: N/A
Issued by UL International (NL) B.V. Notified Body 2821.

Signed:
Name:

Horst Thelen
Head of Notified Body