

Certification Record | CSA Group.

CUSTOMER	CLASS	FILE NUMBER
Federal Signal Corporation 2645 Federal Signal Dr University Park Illinois United States 60484	<u>4812-12</u> SIGNAL APPLIANCES - Audible Devices	005835_0_000

(Replaces: March 5, 2019)

- Horns, resonating type, for indoor or outdoor use; Model 55, 120V, 60Hz, 0.75A with duty cycle of 5 min. "ON", 5 min. "OFF".
- Horns vibrating type, Models 350 with suffixes, 6V, 1.9A; 12V, 0.9A, 24V, 0.9A; 120V, 0.22A; 230-240V, 0.09A ac input.

Note: Suffix letters CC, FB, NB, SF, PR, PR2, FBL or FG are used to indicate thy type of mounting accessories. The suffix letter WB indicates a weatherproof back box for outdoor use.

- Bells, 4, 6, 10 in size, vibrating type, Model 500: 240V and less, 50/60Hz, 1.6A and less; Model 600: 250V dc and less, 1.6A and less; with or without suffix letters CC, FB, FBL, FG, NB, NBL or SF for indoor use and WB (back box) for outdoor use.
- Intercoms, Models 310-MV, (Type 4X), 310-MV-MNC, 24V dc, 0.463A or 120/240V, 50/60Hz, 0.163/0.082A max; microphone conversion kit K850A016 and slave conversion kit K850A017.
- Telcom remote ringer devices, Models TELB 120, TELC 120, TELH 120, TELS 120, 120V, 50/60Hz, 0.24A max.