

CERTIFICATE OF COMPLIANCE

Certificate Number 20140507- E12629
Report Reference E12629-20060602
Issue Date 2014-MAY-07

Issued to: FEDERAL SIGNAL CORP SIGNAL DIV
2645 FEDERAL SIGNAL DR
UNIVERSITY PARK IL 60484

This is to certify that representative samples of AUDIBLE-SIGNAL APPLIANCES FOR USE IN HAZARDOUS LOCATIONS
See addendum page for models

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety:

UL 1480 - Speakers for Fire Alarm, Emergency, and Commercial and Professional Use
UL 1203 - Explosion-Proof and Dust-Ignition Proof Electrical Equipment for Use in Hazardous (Classified) Locations
ANSI/ISA 12.12.01-2013 - Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
CSA C22.2 No. 213-M1987 - Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations
CSA C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations
CSA C22.2 No. 157-92 - Intrinsically Safe Equipment for Use in Hazardous Locations.
CSA C22.2 No. 205-M1983 - Signal Equipment, General Instruction No. 1

Additional Information:

See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20140507- E12629
Report Reference E12629-20060602
Issue Date 2014-MAY-07

Look for the UL Listing Mark on the product.

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL – Speakers for Fire Protective Signaling Systems, Model AM300X and AM302X for use in Hazardous Locations, Class I, Division 1, Groups B, C, and D; Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups F and G; and Class III; Suitable for Outdoor, Wet Locations Use. Also Listed as Speakers and Amplifiers for Fire Protective Signaling Systems.

USL, CNL – Signaling Speakers for General Signaling Systems, Model AM300X and AM302X for use in Hazardous Locations, Class I, Division 1, Groups B, C, and D; Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups F and G; and Class III; Suitable for Outdoor, Wet Locations Use. Also Listed as Speakers.

USL, CNL - Signaling Speakers for General Signaling Systems, Model AM302X-ISMT-100V for use in Hazardous Locations, Class I, Division 1, Groups B, C, and D; Class II, Division 2, Groups F and G; and Class III; Suitable for Outdoor, Wet Locations Use. Also Listed as Speakers.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

