

Certificate of Compliance

Certificate: 1102495

Master Contract: 165016 (LR 11170)

Project: 1102495

Date Issued: May 22, 2001

Issued to: **FEDERAL SIGNAL CORPORATION**
2645 Federal Signal Drive
University Park, IL 60466
USA
Attention: Mr. Owen Price

The products listed below are eligible to bear the CSA Mark shown



Issued by:


D. Lippert

Authorized by:


Brian Rossborough
Operations Manager

PRODUCTS

CLASS 4818 02 - SIGNAL APPLIANCES - Audible - For Hazardous Locations

Class I, Div. 2, Groups A, B, C and D; Class II, Div. 2, Groups F and G; Class III, Type 4X:

Horns vibrating type, Model 350WBX, 120Vac, 50/60Hz, 0.22/0.18A; 240Vac, 50/60Hz, 0.09A, Temperature Code T4A.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No.	94-M91	-	Special Purpose Enclosures
CSA Std C22.2 No.	205-M1983	-	Signal Equipment
CSA Std C22.2 No.	213-M1987	-	Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations

Certificate: 1102495



Master Contract: 165016

Project: 1102495

Date: May 22, 2001

MARKINGS

- CSA monogram
- submitters identification
- model designation
- serial number or date code
- electrical rating
- special purpose enclosure designation
- hazardous locations designation
- temperature code
- cautions for Class I, Div.2 as follows:

"WARNING - EXPLOSION HAZARD - SUBSTITUTION OF COMPONENTS MAY IMPAIR SUITABILITY FOR CLASS I, DIVISION 2"

and

"WARNING - EXPLOSION HAZARD - DO NOT DISCONNECT EQUIPMENT UNLESS POWER HAS BEEN SWITCHED OFF OR THE AREA IS KNOWN TO BE NON-HAZARDOUS"

Note: Jurisdictions in Canada may require these markings to be also in French. It is the responsibility of the Customer to provide bilingual marking, where applicable, in accordance with the requirements of the Provincial Regulatory Authorities.