



Certificate of Compliance

Certificate: 1194086 (LR 5835-46)

Master Contract: 165016

Project: 70076210

Date Issued: 2016-08-04

Issued to: Federal Signal Corporation
2645 Federal Signal Dr
University Park, Illinois 60484
USA

Attention: Sean Moloney

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Yiu-Chi (Edwin)
Ko
Yiu-Chi (Edwin) Ko

PRODUCTS

CLASS - C481285 - SIGNAL APPLIANCES-Signaling Systems - Certified to US Standards

CLASS - C481213 - SIGNAL APPLIANCES-Signal Systems

Strobe lights, indoor/outdoor use, Types 3R/4X, Models FB2PST, FB2PST-I, FB24ST, rated 12-24V dc, 1.7-0.7A, rated 24V dc, 0.7A, or 120V ac, 50/60Hz, 0.25A, or 230-240V ac, 50/60Hz, 0.20A.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 205-12 - Signal equipment
UL 1638 4th Edition - Visual Signaling Appliances - Private Mode Emergency and General Utility Signaling



Supplement to Certificate of Compliance

Certificate: 1194086 (LR 5835-46)

Master Contract: 165016

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70076210	2016-08-04	Update report 1194086 to CSA C22.2 No. 205-12.
1548462	2004-08-19	Update to 1194086 to add Model FTS2PST-I alternate construction of Model FB24ST, deletion of Model FB2MST and FB new ambient temperatures at -40°C and 65°C.
1194086	2001-07-26	Original Certification, Model FB2PST previously evaluated in report LR 5835-46.