



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	6912-0811:0501
CATEGORY:	6912 - VOICE COMMUNICATION ACCESSORIES
LISTEE:	Federal Signal 2645 Federal Signal Drive, University Park, IL, 60466 Contact: Moloney, Sean (708) 534-4878 Email: smoloney@federalsignal.com
DESIGN:	Model UVRI Indoor Electronic Siren Controller unit may be followed by B, BH, BU, B100, BH100 or BU100. Refer to listee's data sheet for detailed product description and operational considerations.
RATING:	24Vdc/120 Vac/240Vac
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed as a voice communication accessory for use with separately listed compatible fire alarm control units. Refer to manufacturer's Installation Manual for details.
NOTES:	

10-08-19 gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 06/14/2022

Listing Expires: 06/30/2023

Authorized By: **Victor Wong**, Program Coordinator
Fire Engineering & Investigations Division