

CERTIFICATE OF COMPLIANCE

Certificate Number 20130710-E207119
Report Reference E207119-20130710
Issue Date 2013-JULY-10

Issued to: FEDERAL SIGNAL CORP SIGNAL DIV
2645 FEDERAL SIGNAL DR
UNIVERSITY PARK IL 60484

This is to certify that representative samples of VISUAL-SIGNAL APPLIANCES FOR USE IN HAZARDOUS LOCATIONS & VISUAL-SIGNAL DEVICES, MARINE


See Addendum Page

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: See Addendum Page

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130710-E207119
Report Reference E207119-20130710
Issue Date 2013-JULY-10

Standard(s) for Safety:

UL 1203 - Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations
UL 50E - Enclosure for Electrical Equipment, Environmental Considerations
UL 50 - Enclosures for Electrical Equipment, Non-environmental Considerations
UL 1638 - Visual Signaling Appliances - Private Mode Emergency and General Utility Signaling
ANSI/ISA 12.12.01-2012 - Non-incendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
CAN/CSA C22.2 No. 25-1966 - Enclosures for Use in Class II Groups E, F, and G Hazardous Locations
CAN/CSA C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations
C22.2 No. 213-M1987 - Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations
CAN/CSA No. C22.2 94.2-07 - Enclosures for Electrical Equipment, Environmental Considerations - First Edition
CAN/CSA C22.2 No. 205-12 - Signal Equipme

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL: Model 24XST strobe light for use in Class I, Div. 1, Groups C and D; Class I, Div. 2, Groups A and B; Class II, Groups E, F, and G; Class III Hazardous Locations; for indoor or outdoor use. Also Listed as a marine visual signal device.

CNL: Model 24XST strobe light for use in Class I, Div. 1, Groups C and D; Class I, Div. 2, Groups A and B; Class II, Groups E, F, and G; Class III Hazardous Locations; for indoor or outdoor use.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

