

CERTIFICATE OF COMPLIANCE

Certificate Number 20150923-E12629
Report Reference E12629-20150921
Issue Date 2015-SEPTEMBER-23

Issued to: FEDERAL SIGNAL CORP SIGNAL DIV
2645 FEDERAL SIGNAL DR
UNIVERSITY PARK IL 60484

**This is to certify that
representative samples of**

AUDIBLE-SIGNAL APPLIANCES FOR USE IN
HAZARDOUS LOCATIONS.

Electronic horn, Model 450EWBX-024 for use in Class I,
Division 2, Groups A, B, C and D; Class II, Division 2,
Groups F and G and Class III Hazardous Locations.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

Standard No. ANSI/ISA 12.12.01, 2013, Nonincendive
Electrical Equipment for Use in Class I and II, Division 2
and Class III, Divisions 1 and 2 Hazardous (Classified)
Locations

Standard No. CAN/CSA C22.2 No. 213-M1987, 1st Ed.,
Non-incendive Electrical Equipment for Use in Class I,
Division 2 Hazardous Locations

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/about/ul/locations/>

